



CERTIFICATE OF COMPLIANCE

Certificate Number: SGSNA/22/SZ/00139X

Contract Number: 801681

Certificate Project Number: SZ-CERT220601362

Certified Product: Smart Meter

Trademarks: CHINT

Model(s): DTSU666

Technical Data: Input: 3 x 57.7/100 V~ to 3 x 240/415 V~, 50/60 Hz, 1.2 W, Class II, Overvoltage category III;
Max operating altitude: 2000 m;
Operating temperature: -25 - 70°C

Certificate Holder: Zhejiang CHINT Instrument & Meter Co., Ltd.
Wenzhou Bridge Industrial Zone, Yueqing, Zhejiang, China

This certificate supercedes previous certificates issued with the same certificate number. Certification is valid when products are indicated on the SGS directory of certified products at www.sgs.com or using the QR code below. The product is certified according to ISO/IEC Guide 17067, Conformity assessment - Fundamentals of product certification, System 3, and in accordance with:

UL 61010-1, 3rd Ed., Rev. July 19, 2019

CAN/CSA C22.2 No. 61010-1-12 Am. 1 (July 19, 2019)

UL 61010-2-030, 2nd Ed., Dec. 21, 2018

CAN/CSA C22.2 No. 61010-2-030, 2nd Ed., 2018

Conditions of Acceptability:

Unit is of building-in type, electrical connections and final installation should be evaluated in end product;

Unit is able to receive current signals converted from external current transformers (CT), comparability and insulation consideration of CTs should be evaluated in end product.

Authorized by:

Effective date: 02 June 2022



Mark Lohmann
Certifier



Certification Body

Consumer and Retail Services, a division of SGS North America Inc.
620 Old Peachtree Road, Ste. 100, Suwanee, GA 30024, USA
t +1 770 570 1800 f +1 770 277 1240 www.sgs.com

