



Ref. Certif. No.

HU-003206

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT
(IECEE) CB SCHEME

CB TEST CERTIFICATE

Product

DC Miniature Circuit Breaker

Name and address of the applicant

SUNTREE Electric Group Co., Ltd.
Xinguang Industrial Zone,
Liushi Town, Yueqing City, Zhejiang, P.R. China

Name and address of the manufacturer

SUNTREE Electric Group Co., Ltd.
Xinguang Industrial Zone,
Liushi Town, Yueqing City, Zhejiang, P.R. China

Name and address of the factory

SUNTREE Electric Group Co., Ltd.
Xinguang Industrial Zone,
Liushi Town, Yueqing City, Zhejiang, P.R. China

Ratings and principal characteristics

Ue=15/24/48/60/100/180/250V DC(1P); 24/48/125/375/500/550/
600/800V DC(2P); 750/900V DC(3P); 1000/1200V DC(4P);
In=6/10/16/20/25/32/40/50/63A; +40 °C; Ui=1250V; Uimp=6kV;
Icu=Ics=6kA; Icu=Ics=2kA (only for 2P,800V / 4P,1200V)

Trademark (if any)

SUNTREE

Customer's Testing Facility (CTF) Stage used

N/A

Model / Type Ref.

SL7N-63

Additional information (if necessary may
also be reported on page 2)

Detailed information refer to test report NN205QEW 001.

A sample of the product was tested and
found to be in conformity with

IEC 60947-2:2016+A1

As shown in the Test Report Ref. No. which
forms part of this Certificate

NN205QEW 001

This CB Test Certificate is issued by the National Certification Body



TÜVRheinland®

TÜV Rheinland InterCert Kft., MEEI Division
H-1143 Budapest, Gizella út 51-57., Hungary
Web:www.tuv.com

Date: 2020-10-13

Signature:

Gergely Bakos